

**BLDG #4C - AUTO FLEET
EMERGENCY POWER INFORMATION**

	Yes	No	Comment
Emergency Generator		X	
Emergency Lighting - Classrooms			NOT APPLICABLE
Emergency Lighting - Hallways		X	
Emergency Lighting - Stairwells			NOT APPLICABLE
Emergency Lighting - Offices		X	
Elevators: Operate during Emergency Power Outage?			NOT APPLICABLE

ADDITIONAL COMMENTS:

Exit sign in garage area, N/E overhead door is misleading – It is not an exit.

Exit/Egress needs to be installed in Auto Fleet Office and in storage area.
