

BLDG #51 - INFORMATION SERVICES BUILDING NO. 2

**COYOTE DRIVE ENTRANCE
EMERGENCY POWER INFORMATION**

	Yes	No	Comment
Emergency Generator		X	
Emergency Lighting - Classrooms			Not Applicable
Emergency Lighting - Hallways			Not Applicable
Emergency Lighting - Stairwells			Not Applicable
Emergency Lighting - Offices		X	
Elevators: Operate during Emergency Power Outage?			Not Applicable

ADDITIONAL COMMENTS:

Only emergency light is in electric room. Install combination exit/egress at entrance door.
